


FILENAME: G04_12-19-06_11:58am.sjpg || XREFS: X-NTP TELK | Mtakamoto-PE=stamp | X-DGellerman-PE=stamp | MTakamoto-PE=stamp | cc=



0" = 1"
— VERIFY SCALES —
BAR IS ONE INCH
LONG ON FULL
SIZE DRAWING.
IF NOT ONE INCH
LONG ON THIS
DRAWING, ADJUST
SCALES ACCORDINGLY



REV	DATE	BY	APVD	DESCRIPTION

DESIGNED M. TOLCHER
DRAWN S. JUNG
CHECKED M. MATSON


SUBMITTED: DENNIS GELLERMAN
RMC PROJ ENGR CE-34684
APPROVED: STEVE CLARY
RMC ENGR CE-30318



NOVATO WASTEWATER FACILITY UPGRADE
LIQUID PROCESS DIAGRAM

DWG NO G-4
SHEET NO
PROJ NO 0049-007
DATE December 2006

FILENAME: G05 12-19-06 11:59am sjung || XREFS: X-NTP TELK M Takamoto-PE=stamp X-DGellerman-PE=stamp M Takamoto-PE=stamp |cc=



0" = 1"
— VERIFY SCALES —
BAR IS ONE INCH
LONG ON FULL
SIZE DRAWING.
IF NOT ONE INCH
LONG ON THIS
DRAWING, ADJUST
SCALES ACCORDINGLY



REV	DATE	BY	APVD	DESCRIPTION

DESIGNED M. TAKEMOTO
DRAWN S. JUNG
CHECKED M. MATSON

SUBMITTED: DENNIS GELLERMAN
RMC PROJ ENGR CE-34684
APPROVED: STEVE CLARY
RMC ENGR CE-30318



NOVATO WASTEWATER FACILITY UPGRADE

SOLIDS HANDLING DIAGRAM



















DWG NO G-5
SHEET NO
PROJ NO 0049-007
DATE December 2006

FILENAME: G06 12-19-06 01:22pm aJung || XREFS: X-NIP TELX | MNGmnto-PE=stamp | X-QCallern-PE=stamp | MTKmnto-PE=stamp | CC=

Design Criteria	Value	Units	Design Criteria	Value	Units	Design Criteria	Value	Units	Design Criteria	Value	Units
Design Year	2025	---	Primary Treatment			RAS Pumps			High Pressure Washwater Pumps		
Average Dry Weather Flow (ADWF)	7.0	MGD	Primary Sedimentation Basins			Type	Submersible		Type	In-Line Multi-Stage	
Average Annual Flow (AAF)	7.8	MGD	Type	Circular	---	Number (installed/standby)	3/1	---	Number (Installed/Standby)	2/1	---
Average Wet Weather Flow (AWWF)	10.3	MGD	Number of Basins	2	---	Capacity (each)	5	MGD	Capacity (each)	60	GPM
Peak Week	17.7	MGD	Design Overflow Rate			TDH	14	Feet	Inlet Pressure	60	psi
Peak Wet Weather Flow, Max Day (PWWF)	30.7	MGD	@ ADWF (7 mgd)	< 800	gpd/sf	Motor Size	35	HP	Required Discharge Pressure	105	psi
Normal Peak 3-Hour Flow	34.6	MGD	@ Peak 3-Hour (47 mgd)	< 3,000	gpd/sf				Motor Size	2	HP
Max Peak 3-Hour Flow	47.0	MGD	Diameter (each basin)	100	feet	Secondary Scum Pumps			Polymer Delivery System		
Average BOD Loading	14,600	lbs/day	Side Water Depth	12	feet	Type	Submersible Chopper		Polymer Type	Emulsion	
Average TSS Loading	17,600	lbs/day				Number (installed/shelf spare)	2/1	---	Number (Installed/Standby)	2/1	---
			Primary Sludge/Scum Pumps			Capacity	150	gpm	Dose, active polymer	8	lbs/ton
Headworks			Type	Progressive Cavity		TDH	36	Feet	Polymer Use (Peak Month)	129	lbs/day
Influent Pump Station			Number (installed/standby)	4/0	---	Motor Size	7.5	HP	Polymer Flow	1.31	GPH
Type	Non-Clog Submersible		Capacity (each)	125	gpm				Polymer Storage (30-day @ Peak Month)	470	gallons
Number (installed/standby)	6/1	---	TDH	39	Feet	WAS Pumps					
Capacity (each)	9.4	MGD	Motor Size	15	HP	Type	Non-Clog Submersible		GBT Filtrate Pumps		
T DH	42.2	feet	*Scum pumps will be used as back-up sludge pumps and vice versa			Number (installed/standby)	2/1	---	Type	Non-Clog Submersible	
Motor Size	125	HP				Capacity (each)	400	GPM	Number (Installed/Standby)	2/1	---
			Secondary Treatment			TDH	19	Feet	Capacity (each)	345	GPM
Septage Receiving Station			Nitrification Operation			Motor Size	5	HP	TDH	39.1	feet
Number	1		MLSS	2,500 - 3,000	mg/l				Motor Size	7.5	HP
Grinder Motor Size	5	HP	Mean cell residence time	8 to 9	days	UV Disinfection					
Auger Motor Size	2	HP	RAS capacity	3-10	mgd	Enterococci Limits			Thickened WAS Pumps		
			Carbonaceous Operation			Peak Day Wet Weather (31 MGD)	35	MPN/100 ml	Number (Installed/Standby)	2/1	---
Mechanical Screens			MLSS	1100 - 1300	mg/l	Peak 3-Hour (47 mgd)	276	MPN/100 ml	Type	Progressive Cavity	
Type	Filter Screen		Mean cell residence time	2.5 - 3	days	Design UV Transmittance	0.55	---	Capacity (each)	40	GPM
Number	2	---	RAS capacity	2.5-5	MGD	Dose	35	mJ/cm ²	TDH	25	feet
Width	4.5	feet				Number of Channels	3	---	Motor Size	3	HP
Openings	15	mm				Channel Width	74	Inches			
			Aeration Basins			Channel Length	33	Feet			
Manual Screens			Number of Basins	4	ea	Channel Side Water Depth	62	Inches	Anaerobic Digestion		
Type	Bar		Volume, each basin	115,300	ft ³				Number of Digesters (1 Existing)	2	
Number	1	---	Side Water Depth	23	ft	UV Channel Air Blower			Volume (each)	571,000	gallons
Width	3.5	feet	Anoxic Zones Volume per Basin	27,600	ft ³	Type	Positive Displacement		Diameter	60	feet
Openings	1	inch				Number	1		Side Water Depth	27	feet
Screenings Conveyor			Aeration Blowers			Capacity	150	SCFM	Volatile Solids Destruction	50	%
Type	Shaftless Screw		Type, Duty	Single-Stage Centrifugal		TDH	6.5	PSI	Design Temperature	98	deg. F
Number	1	---	Type, Standby	Multi-Stage Centrifugal		Motor Size	7.5	HP	Digester Mixing, turnovers	9	per day
Size	14	inch	Number (Installed/Standby)	3/1							
			Capacity (Duty/Standby, each)	4,500/4,000	scfm	Effluent Pumping			Digester Mixing		
			Motor Size	250	HP	Dry Weather			Number (Installed/shelf spare)	1/1	---
Screenings Washers/Compactors			Mixed Liquor Recycle Pumps			Type	Vertical Column		Pump Type	Horizontal Chopper	
Number	1	---	Type	Submersible Propeller		Number (installed/standby)	2/1	---	Capacity (each)	3,600	gpm
Compactor Motor Size	3	HP	Number (installed/standby)	4/0	---	Capacity (each)	11	MGD	TDH	16.7	feet
Grinder Motor Size	10	HP	Capacity (each)	3.5	MGD	TDH	22	Feet	Motor Size	30	HP
			TDH	1	Feet	Motor Size	60	HP			
Grit Chamber			Motor Size	2.5	HP	Wet Weather			Digester Recirculation Pumps		
Type	Vortex		Submersible Mixers			Type	Vertical Turbine		Number (Installed/Standby)	2/1	---
Number	2	---	Type	Submersible		Number (installed/standby)	3/1	---	Pump Type	Screw Centrifugal	
Diameter	16	feet	Number (installed/standby)	12/0	---	Capacity (each)	23.5	MGD	Capacity (each)	200	gpm
Capacity (each)	23.5	MGD	Motor Size	2.5	HP	TDH	57	Feet	TDH	14.5	feet
Motor Size	3	HP				Motor Size	300	HP	Motor Size	5	HP
			Secondary Drainage Pump			Utility Water Pumps			Digested Sludge Pumps		
Grit Pumps			Type	Submersible		Type	Vertical Turbine		Number (Installed/Standby)	2/1	---
Type	Recessed Impeller		Number (installed/standby)	1/0	---	Number (installed/standby)	3/1		Pump Type	Progressive cavity	
Number (installed/standby)	2		Capacity	1800	GPM	Capacity (each)	750	gpm	Capacity (each)	95	gpm
Capacity (each)	300	GPM	TDH	27	Feet	TDH	200	Feet	TDH	344	feet
TDH	29	feet	Motor Size	20	HP	Motor Size	60	HP	Motor Size	20	HP
Motor size	7.5	HP									
			ML Channel Air Blower			Solids (WAS) Thickening			Ferric Chloride Pumps		
Grit Cyclones			Type	Positive Displacement		Gravity Belt Thickeners			Number (Installed/Standby)	2/0	---
Type	Centrifugal		Number	1/0	---	Number (Installed/Standby)	2/1	---	Pump Type	Peristaltic	
Number	2	---	Capacity	450	SCFM	Belt width	1	meter	Capacity (each)	15	gph
Capacity (each)			TDH	3.5	PSI	Belt Drive Motor Size	2	HP			
Inlet	300	GPM	Motor Size	10	HP	Hours of Operation (Nitrification)	10	hours/day	Hypochlorite Pumps		
Under flow	16	GPM				Hours of Operation (Carbonaceous)	16	hours/day	Number (Installed/Standby)	3/1	one existing
			Secondary Clarifiers			Maximum Solids Loading Rate	700	lbs/hr/meter	Pump Type	Diaphragm	
Grit Classifier			Solids Flux Rate			Maximum Hydraulic Loading Rate	200	gpm/meter	Capacity (new, each)	12.0	gph
Type	Screw Conveyor		Average Dry Weather Flow	8.25	lbs/ft ² /d	Solids Capture	95	%	Capacity (existing, each)	77	gph
Number	2	---	Type	Circular		Thickened WAS Solids Concentration	5	%	Motor Size	0.5	HP
Size	12	inches	Number of Clarifiers	2	---						
Motor Size	2	HP	Design Overflow Rate								
			@ ADWF (7 MGD, 2 Basins)	407	gpd/ft ²						
Influent Metering			@ Max Peak 3-Hour (47 mgd)	2,320	gpd/ft ²						
Parshall Flumes			Diameter (each clarifier)	125	ft						
Number	2	---	Side Water Depth	16	ft						
Throat Width	30	inches									



0"=1"
--- VERIFY SCALES ---
BAR IS ONE INCH
LONG ON FULL
SIZE DRAWING.
IF NOT ONE INCH
LONG ON THIS
DRAWING, ADJUST
SCALES ACCORDINGLY



DESIGNED M. TOLCHER
DRAWN S. JUNG
CHECKED M. MATSON

SUBMITTED: DENNIS GELLERMAN
RMC PROJ ENGR CE-34684
APPROVED: STEVE CLARY
RMC ENGR CE-30318



NOVATO WASTEWATER FACILITY UPGRADE

DESIGN CRITERIA


DWG NO G-6

SHEET NO


PROJ NO 0049-007

DATE December 2006

LIQUID STREAM & SOLIDS SAMPLE LOCATIONS



SOLIDS STREAM SAMPLE LOCATIONS



NOVATO WASTEWATER FACILITY UPGRADE
SOLIDS HANDLING DIAGRAM
DATE: December 2006



REV	DATE	BY	APPROVED	DESCRIPTION
1				
2				
3				
4				
5				

DESIGNED: M. TAKEMOTO	SUBMITTED: DENNIS GELLMAN
DRAWN: S. JUNG	ANALYST: ENR
CHECKED: M. MATSON	APPROVED: STEVE CLARY
	ANALYST: ENR



NOVATO WASTEWATER FACILITY UPGRADE
SOLIDS HANDLING DIAGRAM
DATE: December 2006

DSW NO	G-5
SHEET NO	
PROJ NO	0048407
DATE	December 2006