

Work Orders: 7C03049

Report Date: 3/09/2017

Received Date: 3/3/2017

Project: Carlsbad Desal Plant - WEEKLY

Turnaround Time: Normal

Phones: 1(619) 487-0760

Fax:

Attn: Peter Shen

P.O. #:

Client: IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Billing Code:

ELAP-CA #1132 • EPA-UCMR #CA00211 • LACSD #10143 • NJ-DEP #CA015 • NV-DEP #NAC 445A

This is a complete final report. The information in this report applies to the samples analyzed in accordance with the chain-of-custody document. Weck Laboratories certifies that the test results meet all requirements of TNI unless noted by qualifiers or written in the Case Narrative. This analytical report must be reproduced in its entirety.

Dear Peter Shen,

Enclosed are the results of analyses for samples received 3/03/17 with the Chain-of-Custody document. The samples were received in good condition, at 1.5 °C and on ice. All analyses met the method criteria except as noted in the case narrative or in the report with data qualifiers.

Reviewed by:



Hai Van Nguyen
Senior Project Manager





WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Certificate of Analysis

FINAL REPORT

Project Number: Carlsbad Desal Plant - WEEKLY

Reported:

03/09/2017 08:58

Project Manager: Peter Shen

Sample Summary

Sample ID	Sampled By	Lab ID	Matrix	Sampled	Qualifiers
M-001	Client	7C03049-01	Water	03/02/17 08:22	
M-INF	Client	7C03049-02	Water	03/02/17 05:35	
M-002	Client	7C03049-03	Water	03/02/17 05:40	

Not Certified Analyses Summary

Analyte	CAS #	Not Accredited By
SM 2520B in Water		
Salinity		NELAP



WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Certificate of Analysis

FINAL REPORT

Project Number: Carlsbad Desal Plant - WEEKLY

Reported:

03/09/2017 08:58

Project Manager: Peter Shen

Sample Results

Sample: M-001

Sampled: 03/02/17 8:22 by Client

7C03049-01 (Water)

Analyte	Result	MDL	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-----	-------	-----	----------	-----------

Conventional Chemistry/Physical Parameters by APHA/EPA/ASTM Methods

Method: EPA 1664A	Batch ID: W7C0303	Prepared: 03/06/17 16:26		Analyst: joh	
Oil & Grease (HEM)	ND	1.3	5.0 mg/l	1	03/07/17 15:55
Method: SM 2520B	Batch ID: W7C0345	Prepared: 03/07/17 10:14		Analyst: dmn	
Salinity	36		ppt	1	03/07/17 10:53
Method: SM 2540D	Batch ID: W7C0285	Prepared: 03/06/17 13:51		Analyst: ajk	
Total Suspended Solids	18	5	mg/l	1	03/06/17 15:55



WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Certificate of Analysis

FINAL REPORT

Project Number: Carlsbad Desal Plant - WEEKLY

Reported:

03/09/2017 08:58

Project Manager: Peter Shen

Sample Results

(Continued)

Sample: M-INF

Sampled: 03/02/17 5:35 by Client

7C03049-02 (Water)

Analyte	Result	MDL	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-----	-------	-----	----------	-----------

Conventional Chemistry/Physical Parameters by APHA/EPA/ASTM Methods

Method: SM 2520B

Batch ID: W7C0345

Prepared: 03/07/17 10:14

Analyst: dmn

Salinity	27	ppt	1	03/07/17 10:53
----------	----	-----	---	----------------



WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Project Number: Carlsbad Desal Plant - WEEKLY

Project Manager: Peter Shen

Certificate of Analysis

FINAL REPORT

Reported:
03/09/2017 08:58

Sample Results

(Continued)

Sample: M-002
7C03049-03 (Water) Sampled: 03/02/17 5:40 by Client

Analyte	Result	MDL	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-----	-------	-----	----------	-----------

Conventional Chemistry/Physical Parameters by APHA/EPA/ASTM Methods

Method: SM 2520B	Batch ID: W7C0345	Prepared: 03/07/17 10:14	Analyst: dmn
Salinity -----	30	ppt	1 03/07/17 10:53



WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Certificate of Analysis

FINAL REPORT

Project Number: Carlsbad Desal Plant - WEEKLY

Project Manager: Peter Shen

Reported:
03/09/2017 08:58

Quality Control Results

Conventional Chemistry/Physical Parameters by APHA/EPA/ASTM Methods

Analyte	Result	MDL	Units	Spike Level	Source Result	%REC	Limits	RPD	Limit	Qualifier
Batch: W7C0285 - SM 2540D										
Blank (W7C0285-BLK1)				Prepared & Analyzed: 03/06/17						
Total Suspended Solids	ND		mg/l							
LCS (W7C0285-BS1)				Prepared & Analyzed: 03/06/17						
Total Suspended Solids	56.0		mg/l	52.9		106	90-110			
Duplicate (W7C0285-DUP1)				Source: 7C03049-01 Prepared & Analyzed: 03/06/17						
Total Suspended Solids	19.0		mg/l		18.0			5	20	
Batch: W7C0303 - EPA 1664A										
Blank (W7C0303-BLK1)				Prepared: 03/06/17 Analyzed: 03/07/17						
Oil & Grease (HEM)	ND	1.3	mg/l							
LCS (W7C0303-BS1)				Prepared: 03/06/17 Analyzed: 03/07/17						
Oil & Grease (HEM)	19.8	1.3	mg/l	20.0		99	78-114			
LCS (W7C0303-BS2)				Prepared: 03/06/17 Analyzed: 03/07/17						
Oil & Grease (HEM)	4.90	1.3	mg/l	5.00		98	78-114			J
LCS Dup (W7C0303-BSD1)				Prepared: 03/06/17 Analyzed: 03/07/17						
Oil & Grease (HEM)	19.9	1.3	mg/l	20.0		100	78-114	0.5	18	
Batch: W7C0345 - SM 2520B										
Duplicate (W7C0345-DUP1)				Source: 7C03049-03 Prepared & Analyzed: 03/07/17						
Salinity	29.8		ppt		29.8			0.2	20	



WECK LABORATORIES, INC.

IDE Americas, Inc. - Carlsbad CA
4590 Carlsbad Blvd
Carlsbad, CA 92008

Certificate of Analysis

FINAL REPORT

Project Number: Carlsbad Desal Plant - WEEKLY

Project Manager: Peter Shen

Reported:
03/09/2017 08:58



Notes and Definitions

Item	Definition
J	Estimated conc. detected <MRL and >MDL.
ND	NOT DETECTED at or above the Method Reporting Limit (MRL). If Method Detection Limit (MDL) is reported, then ND means not detected at or above the MDL.
Dil	Dilution
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
% Rec	Percent Recovery
Source	Sample that was matrix spiked or duplicated.
MDL	Method Detection Limit
MRL	The minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence. The MRL is also known as Limit of Quantitation (LOQ) and Detection Limit for Reporting (DLR)
MDA	Minimum Detectable Activity
NR	Not Reportable
TIC	Tentatively Identified Compound (TIC) using mass spectrometry. The reported concentration is relative concentration based on the nearest internal standard. If the library search produces no matches at, or above 85%, the compound is reported as unknown.

Any remaining sample(s) will be disposed of one month from the final report date unless other arrangements are made in advance.

An Absence of Total Coliform meets the drinking water standards as established by the California State Water Resources Control Board (SWRCB)

All results are expressed on wet weight basis unless otherwise specified.

All samples collected by Weck Laboratories have been sampled in accordance to laboratory SOP Number MIS 002.